



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/11/2025

Shift: B

Incharge(s): Nagendra Midde, M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29	M3 TRIPPED	RESET	21:20:00	21:35:00	
2	OHP	WBR ON CO 6A NO DRIVE RUNNING	DOWN EMERGENCY LIMIT ACTED	RELEASED	17:30:00	18:00:00	
3	OHP	BRC ON CO 30 B/C	ZSS INTERLOCK CAGE CAUTER PIN BROKEN	REPLACED	21:45:00	22:00:00	
4	CHP	CC 201	OLR ACTED	RESET	14:30:00	14:45:00	
5	CHP	SCR 5 ON CC 33 SLEW	OLR ACTED	RESET	16:20:00	16:40:00	
6	CHP	SCR 2 ON CC 39	LT O/T ACTED	RELEASED	15:35:00	15:45:00	
7	CHP	SCR 6 ON CC 38	B/C OLR ACTED	RESET	16:05:00	16:15:00	
8	CHP	SCR 4 ON CC 31 LT	O/T ACTED	RESET	19:15:00	19:25:00	
9	CHP	SCR 2 ON CC 39 LT	PCRD O/T ACTED	RELEASED	20:40:00	20:50:00	
10	CHP	CC 103 F/G	OLR ACTED	RESET	15:30:00	15:45:00	
11	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	21:10:00	21:15:00	
12	CHP	CC 54	OLR ACTED	RESET	21:45:00	21:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/11/2025

Shift: B

Incharge(s): Nagendra Midde, M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OT4	DRIVE 2 TRIPPED ON PGF1 FAULT	RESET	15:10:00	15:15:00	