



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	17:40:00	17:50:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	18:00:00	18:10:00	
3	OHP	CO-12 B/D	OLR ACTED	RESET DONE	18:40:00	18:50:00	
4	OHP	CO-25	OLR ACTED (2TIMES)	RESET DONE	20:40:00 21:00:00	20:50:00 21:01:00	
5	CHP	CC-132	OLR ACTED	RESET DONE	19:50:00	20:00:00	
6	CHP	CC-36 S-2	REPORTED LT NOT TAKING PLACE FOUND HT CABLE JOINT PART STUCK UP IN PCRD GUIDE	RELEASE IT THAN OK	14:35:00	14:55:00	
7	CHP	CC-36 S-2	LT NOT TAKING PLACE CHECKED PCRD GUIDE PROBLEM	INFORM TO MECHANICAL INC PCRD CABLE UN WINDING CABLE LOOP GIVEN AND DRUM ARREST PCRD MOTOR OUTGOING REMOVED	16:30:00	18:50:00	
8	IOSA	OC-9A, OC-11A	REPORTED NOT HEALTHY CHECKED AND FOUND LC-3 I/C-1 TRIPPED	BUS COUPLER CHARGED	17:30:00	17:45:00	NOW I/C-2 AND B/C WORKING