



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	reset done	16:15:00	16:20:00	
2	OHP	CO 28 , BRC	BW 2 not running	Chain fallen , informed to operation	18:10:00	18:25:00	
3	OHP	BRC on CO 32	LT brakes not operating	Brakes tight , informed mechanical for adjustment	19:20:00	20:00:00	No electrical problem
4	OHP	CO 32	BRS bypassed	On operation request	20:20:00	20:30:00	
5	OHP	CO 34	Overload acted	reset done	18:40:00	18:50:00	
6	CHP	CC 32	BRS to be bypassed	Bypassed as per operation request	14:30:00	14:40:00	again kept in circuit
7	CHP	CC 115	BRS in bypassed condition	kept in circuit	17:15:00	17:30:00	
8	CHP	CC 35	BRS to be bypassed	Bypassed as per operation request	20:25:00	20:30:00	IN system
9	CHP	CC 117	Tripped in overload	reset done	18:10:00 19:25:00	18:25:00 19:40:00	
10	CHP	CC 54	Tripped in overload	reset done	21:10:00	21:15:00	
11	CHP	CC 21	ZSS cage problem	cage replaced	19:10:00	19:35:00	
12	CHP	CC 131	Tripped in overload	reset done	21:55:00	22:00:00	
13	WT	OP 5	Drive 1 overload	reset done	20:25:00	20:35:00	
14	WT	OP 5	Anti collision sensor frequently acted	Bypassed	21:20:00	21:30:00	