



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/01/2026

Area: WT

| Equipment | Job |
|----------------|--------------------------------------------------------------------------------------------------------|
| OP 2 | All Motors meggering and control checking done 1AT,2AT,3AT timers time adjusted (12,7,6 sec) |
| CP 4 | Top power collector set replaced and Trolley Line inspection and top bus bar alignment done @73 and 33 |
| OP 6 | Section isolaters maintenance done 3 nos (Line completed) |
| OP 1,5,6 and 8 | After rake maintenance done |
| CP 1 and 4 | After rake maintenance done |
| MIS | LC 10B room cleaning done |