



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	REPORTED NOT HEALTHY OLR ACTED	OLR RESET	05:00:00	05:15:00	
2	OHP	WOBR ON CO-6A	PENDING FROM B SHIFT.REPORTED HYDRAULIC PUMP NOT STARTING.	CHECKED AND FOUND HYDRAULIC PUMP 1 CONTROL ON. HYDRAULIC PUMP 1 CONTROL MADE OFF AND TESTED OKAY.	22:00:00	23:00:00	
3	OHP	CO-16	BRS CABLE GOT CUT DUE TO CLEANING VIA BOBCAT	BRS CABLE JOINT DONE AND BRS RESTORED AND KEPT IN LINE	22:00:00	00:00:00	NO ELECTRICAL DELAY
4	CHP	CC-23	STOPPING ON ZSS FAULT	ZSS CAGE STUCK WITH COAL MATERIAL.MADE FREE AND TESTED OKAY	22:40:00	22:50:00	
5	CHP	CC-51A	REPORTED NOT HEALTHY	OLR ACETED.RESET DONE(3TIMES)	00:20:00 02:35:00 02:45:00	00:25:00 02:40:00 02:55:00	
6	CHP	CC-114	REPORTED NOT HEALTHY	OLR ACTED.RESET DONE	03:15:00	03:25:00	
7	CHP	CC113	REPORTED NOT HEALTHY	OLR ACTED.RESET DONE(4 TIMES)	03:50:00 04:35:00 05:20:00 05:50:00	04:00:00 04:45:00 05:30:00 06:00:00	
8	CHP	CC-51	REPORTED NOT HEALTHY	OLR ACTED.RESET DONE(2TIMES)	00:25:00 22:00:00	00:30:00 22:10:00	
9	CHP	CC-54	REPORTED NOT HEALTHY	OLR ACTED.RESET DONE	02:10:00	02:15:00	
10	CHP	CC-36 SCR-1	REPORTED LT NOT TAKING PLACE	CHECKED AND FOUND TO BE OKAY	23:25:00	23:35:00	WRONG COMPLAINT



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/08/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC40 SCR-3	REPORTED SLEW AND LUFFING NOT WORKING	CHECKED AND FOUND SLEW AREA JAMMING.LUFFING FOUND TO BE OKAY	23:55:00	00:15:00	INFORMED TO OPERATION.AFTER CLEANING FOUND TO BE OKAY
12	CHP	CC36 SCR-1	BOOM POSITION INDICATION NOT COMING TO CCR	BOOM INDICATION BYPASSED AND CLEARANCE GIVEN	00:20:00	00:35:00	
13	CHP	CC39 SCR-7	REPORTED B/C NOT RUNNING	CHECKED AND FOUND DISCHARGE CHUTE AREA JAMMING.	00:40:00	01:00:00	INFORMED TO OPERATION.AFTER CLEANING FOUND TO BE OKAY
14	CHP	CC-105 SCR-10	B/C NOT RUNNING	CHECKED AND FOUND DISCHARGE CHUTE SENSOR ACTED DUE TO RAIN. CHUTE SENSOR BYPASSED.	01:00:00	01:20:00	
15	CHP	CC-35 S-2	REPORTED LT NOT WORKING	CHECKED AND FOUND DRIVE TRIPPED. RESET DONE	03:30:00	03:45:00	
16	CHP	CC-40 SCR-3	REPORTED B/C NOT RUNNING	OLR ACTED.RESET DONE	03:30:00	03:40:00	
17	CHP	CC-40 SCR-3	B/C STOPPING FREQUENTLY	ZSS CAGE STUCK UP.BYPASSED	03:15:00	04:15:00	INFORMED TO A SHIFT



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
18	CHP	CC-31 SCR-4	B/C NOT RUNNING	CHECKED AND FOUND DISCHARGE CHUTE SENSOR ACTED.BYPASSED	05:25:00	05:35:00	
19	CHP	CC-36 SCR-1	B/C NOT RUNNING	CHECKED AND FOUND DISCHARGE CHUTE SENSOR ACTED.AFTER CLEANING SENSOR FOUND TO BE OKAY	05:20:00	05:40:00	
20	WT	OP-5	REPORTED NOT MOVING AT COUPLING TIME	DRIVE 5 OLR ACTED.RESET DONE	00:15:00	00:30:00	
21	WT	OP-3	REPORTED NOT MOVING	DRIVE-1 OLR ACTED.RESET DONE	05:40:00	05:50:00	