



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/06/2025

Area: WT

Equipment	Job
CP4	panel and motor side PPM done
OP3	After rake maintenance done,one jumper also replaced
OP10	D4 Burnt motor. coupling removed and fixed in spare motor ,, Burnt motor sent to ERS
OP10	D4 motor autotuning and testing done, kept in ckt