



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/05/2025

Area: OHP

Equipment	Job
CR2A lubricaiton	filter clog switch is found bypassed, kept back in circuit.
rsco-9a,rsco-6a,co-14b,13a, ios a interfacing DI bits	io bits of respective feeders including their position bits have been relocated as per new chart available at LC3 rio location.
co-13a,14a,14b,rsco-6a	motor side vibration inspection is done and recorded.
co-10a,rsco-1a,rsco-2a,rco-6a,vs-1 apanel	apanel side and motor side running inspection is done, abnormal sound has been observed from rsco-2a belt drive gearbox, informed mechanical.