



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/11/2025

Area: WT

| Equipment | Job |
|--------------------|--|
| OP 3 | New motor shifted and placed in D6 and alignment done(termination is pending) |
| OP 3 | D2 motor re alignment done after Mech. clearance due to bed misalignment |
| OP 3 | control circuit checked and 5A1 rotor contactor cleaning and panels blowing done |
| OP 10 | stand by PLC installed and testing done |
| CT 2 hopper | 200 W,LED light fitting replaced near M2 |
| CC 2 and staircase | Lighting ,CC 2 area circuit problem rectified and staircase 8 nos tubes replaced |
| CO 4 | 120 W LED replaced @ tail end area |
| OP 2,3,5,7 and 9 | After rake maintenance done |