



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/12/2025

Area: IOSA

Equipment	Job
TBS	ALL PLC BITS FEEDBACK CHECKED IN PROGRAM.
BLENDER RECLAIMER	LT DRIVE-1 PARAMETER CHECKED AND TRIAL RUN TAKEN.
OC-23A	GALLERY LIGHTING CIRCUIT RECTIFICATION IS IN PROGRESS. MINIMUM LIGHTING PROVIDED.
OC-6A	INSPECTION DONE ON FIELD DEVICES
OC-3A	PPM DONE ON MOTOR AND FIELD DEVICES.