



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/12/2025

Area: WT

| Equipment | Job |
|------------------|---|
| CM 7 | Data cable panel blowing done and 2 nos tubes replaced |
| CO 3 and 4 area | Lighting problem rectified, 1 no 200 W LED and 15 mtrs cable replaced |
| CO 4(Belt) | NGEF module ,sliding contact replaced |
| OP 3,4,5,7 and 9 | After rake maintenance done |