



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 30	LT PCRD O/T ACTED	RELEASED	15:25:00	15:40:00	
2	OHP	BRC ON CO 32	ZSS INTERLOCK NOT COMING DUE LOOSE CONNECTION IN MODULE	TIGHTENED THEN OK	16:05:00	16:20:00	
3	OHP	BRC ON CO 30	LT BREAK MPCB 2 TRIPPING FREQUENTLY	BREAKS LOOSEN AND OUT GOING CABLES IN MPCBS REMOVED	18:00:00	19:15:00	TO BE CHECKED
4	OHP	BRC ON CO 33M LT	PCRD GUIDE PROBLEM INFORMED TO MECH	LOOP GIVEN	20:45:00	21:10:00	
5	OHP	RSCO 10A CD	OLR ACTED	RESET	19:00:00	19:15:00	
6	OHP	CO 62	MPCB TRIPPED DUE TO BELT CUT	RESET ABD INFORMED TO OPRN	19:20:00	19:30:00	
7	CHP	CC 51	FEEDING CONV MPD TRIPPED	RESET	15:40:00	16:50:00	3 TIMES
8	CHP	RG3	BUNKER INDICATION PROBLEM	INSTRUMENTATION CHECKING UNDER PROCESS	18:00:00	22:00:00	
9	CHP	CC 28	OLR ACTED	RESET	19:30:00 20:00:00	19:40:00 20:10:00	
10	CHP	SCR1 ON CC 36	PCRD CABLE FELL DOWN CHAIN PROBLEM	AFTER MECH CLEARANCE WINDING DONE	15:00:00	16:00:00	
11	CHP	R1 ON CC 32	B/C STOPPING DUE TO INTERLOCK ZSS CAGE GETTING STUCK WITH COAL PIECE	REMOVED THEN OK	17:20:00	17:40:00	
12	CHP	SCR 6 ON CC 38 LT	M1 TRIPPED	RESET	16:20:00	16:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	SCR 6 ON CC 38	TUL C/S MODULE REPLACED	KEPT IN CIRCUIT	17:30:00	18:10:00	
14	CHP	CC 32	OLR ACTED	RESET	18:10:00	18:20:00	
15	CHP	scr 7 on cc 37	SLEW BREAK FAIL	RESET	19:00:00	19:15:00	
16	CHP	SCR 5 ON CC 33	LT DRIVE TRIPPED	RESET	21:15:00	21:25:00	
17	WT	OT1	DRIVE 1 TRIPPED IN PGF1 FAULT	RESET	15:45:00	15:55:00	
18	WT	CP2	COMMUNICATION FAULT	POE POWER RECYCLED THEN OK	21:20:00	21:35:00	