



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/08/2025

Area: OHP

Equipment	Job
tbs-24	flash over took place in coupler, 2 fuses blown , dnw are on job,
brc-3	shifted from co-32 to co-8a
tbs-20	cjd and boom run indication is restored to normal.