



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/11/2025

Area: CHP

Equipment	Job
SCR 6	Communication Antenna replaced and connections tightened
SCR 3	Boom conveyor ZSS cage replaced
CC 114	Extra ZSS installed and wired up to CM 24 IO rack
CC 41,43,45,46,47,48,49,50	Running inspection was done
CC 36,S 2, CC 12,20,21	PPM was done
S 1	HT coupler maintenance was done
Transfer car	Cable jointed and charged supply
SCR 1 Repair bay	LT motor and slew motors termination done. All drives tested
S1,SCR 1	Yard machine shifting done