



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 38 B	c/s problem o/p not coming,	bypassed as per operation request	07:20:00	07:30:00	
2	OHP	TT2	LT not working,mpcb tripped,cable old joint shorted	old joint rejoined,mpcb made on	08:00:00	08:30:00	
3	OHP	BRC on Co 8A	B/w 1 not running,olr acted	reset	11:15:00	11:30:00	
4	OHP	wobr on 29	b/w not running,mpcb tripped	mpcb made on	12:45:00	13:00:00	
5	CHP	CC 112 scr 8	b/w not running,	electrical all ok,mechanical pressed manually solenoid than ok	07:29:00	08:00:00	
6	CHP	CC 36 SCR1	b/w not running,olr acted	reset it done	09:20:00	09:30:00	
7	CHP	CC 112 SCR8	B/W not running,loose connection of fuse TB 12 to XMD for b/w	direct loop given	11:20:00	11:55:00	
8	WT	CP 2	slow movement,1AT timer neutral opened	neutral connected of 1AT	09:15:00	09:25:00	
9	IOSA	communication problem	all conveyor red,	processor B made off and processor a kept on,and power recycle done in AUGOM-1,4,1-142LC1,LC2,LC3	06:30:00	07:30:00	
10	IOSA	COMMUNICATION problem all R I/O niu red	all conveyor red	in AUG OM 4 GE bus connector to NIU cable swap for PLC A and B,power recycle of plc in AUGOM-1,4,1-142LC1,LC2,LC3	07:50:00	08:20:00	
11	IOSA	OC 33A	zss problem,material stucked in ZSS	material removed	11:16:00	11:30:00	
12	IOSA	old WOBR	LT not taking place drive trips in LVN	reset it done	12:25:00	12:40:00	