



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/06/2025

Incharge(s): K SANKARA RAO

Shift: B

| Sl No | Area | Equipment   | Problem                                  | Action                                     | From     | To       | Remarks                             |
|-------|------|-------------|--|--|----------|----------|-------------------------------------|
| 1     | OHP  | CO 9        | ELECTRONIC OLR ACTED (3TIMES)            | RESET                                      | 17:30:00 | 21:00:00 |                                     |
| 2     | CHP  | CC 131      | OLR ACTED (2TIMES)                       | RESET                                      | 16:45:00 | 17:30:00 |                                     |
| 3     | CHP  | CC 132      | OLR ACTED                                | RESET                                      | 19:50:00 | 20:00:00 |                                     |
| 4     | CHP  | CC 32 SCR 5 | LT NOT TAKING PLACE E/STOP ACTED         | RELEASED AND POWER RECYCLED THAN OK        | 14:30:00 | 14:40:00 |                                     |
| 5     | CHP  | CC 111 S3   | LUFFING NOT TAKING PLACE MCCB TRIP       | MADE ON                                    | 14:45:00 | 15:00:00 | DUE TO OIL LEAKAGE INFORMED TO MECH |
| 6     | CHP  | CC 35 SCR2  | LT NOT WORKING O/T ACTED                 | RELESED                                    | 17:00:00 | 17:20:00 |                                     |
| 7     | CHP  | CC 32 SCR5  | LT NOT WORKING O/T ACTED                 | RELEASED                                   | 18:00:00 | 18:20:00 |                                     |
| 8     | CHP  | CC35        | D/E SIDE C/S NOT WORKING PROBE CABLE CUT | MODULE TO PROBE NEW CABLE REPLACED THAN OK | 18:35:00 | 19:05:00 |                                     |
| 9     | CHP  | CC 111 S3   | SIGNAL MISSING (2TIMES)                  | LT FORWARD MOVES SIGNAL THAN HEALTHY       | 19:30:00 | 21:25:00 |                                     |
| 10    | WT   | OT 3        | D 1 TRIP                                 | RESET                                      | 19:45:00 | 19:50:00 |                                     |