



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2025

Shift: A

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|--------------------------------------|----------|----------|----------------------------|
| 1 | OHP | co 11 C/D | tripped on mpcb due to jamming | mpcb made on | 09:30:00 | 09:45:00 | |
| 2 | OHP | tt 4 on co 19 | chute position signal not getting to ocr/mpcb tripped and not getting on | c/s bypassed at c/s relay then ok | 09:30:00 | 09:45:00 | |
| 3 | OHP | cc 27a | brs acting due to water | bypassed for operation requirement | 07:50:00 | 08:00:00 | brs kept in ckt at 12.15pm |
| 4 | OHP | co 3a | zss acting/material jamming at tailend | kept in local mode and again in plc | 11:30:00 | 12:10:00 | |
| 5 | OHP | co 11 C/D | TRIPPED ON MPCB DUE TO JAMMING | mpcb made on | 10:45:00 | 10:45:00 | |
| 6 | CHP | cc202 | zss was in bypassed | zss module replaced and kept in ckt | 09:30:00 | 09:50:00 | |
| 7 | CHP | scr 5 on cc32 | It not taking place/m 6 mpcb tripped | mpcb made on.then ok | 06:40:00 | 06:50:00 | |
| 8 | CHP | scr 5 on cc32 | bc not running/chute and deck sheets jamming | inform to operation | 07:15:00 | 08:15:00 | c/s bypassed of bc |
| 9 | CHP | cc 223 | control missing/c/s acted due to jamming | reset after cleaning | 07:00:00 | 07:10:00 | |
| 10 | CHP | scr 8 on cc112 | It not taking place/pcrd cable fallen and mpced tripped | mpcb made on then cable winding done | 10:05:00 | 10:15:00 | |
| 11 | CHP | cc 202 | zss acting/speed setting in zero | speed setting adjusted, | 11:15:00 | 12:05:00 | |
| 12 | CHP | scr 5 on cc32 | It not taking place/m 6 mpcb tripped | mpcb made on then ok | 13:00:00 | 13:10:00 | |
| 13 | CHP | cc 26a | c/s acted | reset done | 11:05:00 | 11:15:00 | due material |
| 14 | CHP | cc 51 | zss acted/belt snap | inform to operation | 08:55:00 | 09:05:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2025

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|--|----------|----------|--|
| 15 | WT | cp 9 | forward /reverse not taking place/communication problem | plc power recycled done. this problem occurring frequently | 06:45:00 | 07:30:00 | pusher forward done in local mode up to inhaulzone then kept in remote |