



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/08/2025

Area: WT

Equipment	Job
EOT Crane(O)	Panels ,J Bs and motors blowing done
MIS	pedestal fan @CO2 checked ,found motor burnt,dismantling done
OP 2 and 7	After rake maintenance done