



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	17:35:00	17:45:00	
2	OHP	CO-32	Reported tripped	OLR acted.Reset done	18:20:00	18:30:00	
3	OHP	TBS on CO-5A	Reported LT not working	M-1,M-2 tripped due to track jamming.Reset done	17:10:00	17:20:00	No delay
4	CHP	CC-29	Reported tripped	OLR acted due to jamming.Reset done(3 times)	15:30:00	17:00:00	
5	CHP	CC-29 to CO-111	Reported signal not coming	Wire loose at I/O rack.tightened and tested okay	14:30:00	14:45:00	
6	CHP	CC-54	Reported tripped	OLR acted.Reset done(2times)	16:45:00	16:55:00	
7	CHP	Cc-51	Reported tripped	MPD tripped.Reset done	17:55:00	18:00:00	
8	CHP	CC-132	Reported tripped	OLR acted.Reset done	19:00:00	19:10:00	
9	CHP	RG-1	Reported tripping on vibration fault	Informed to mechanical	18:50:00	19:10:00	
10	CHP	Cc-111 SCR-8	Reported signal missing	LT done and tested okay	15:53:00	16:15:00	
11	CHP	Cc-125	Reported tripped	OLR acted.Reset done	16:50:00	17:00:00	
12	CHP	Cc-40 SCR-2	Reported Lt not working	PCRD OT acted.Released and tested okay(3 times)	17:23:00	20:38:00	
13	CHP	CC-112 s-3	Reported B/C not running	OLR acted.Reset done	20:40:00	20:50:00	
14	CHP	CC 105 SCR 10	LT not working	Track jamming.Informed to operation	16:25:00	16:35:00	
15	WT	CO-2	Reported healthy but not running	Checked and found TIS-3 Fb not coming.Bypassed in program and tested okay	17:23:00	17:32:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	IOSA	OC-27A	Reported stopping on ZSS	Checked and found Cage getting stuck due to material falling.Belt problem(2 times)	14:55:00	21:50:00	