



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment     | Problem  | Action   | From                 | To                   | Remarks                |
|-------|------|---------------|--|--|----------------------|----------------------|------------------------|
| 1     | OHP  | tbs on co-5a  | L/LUFF NOT TAKING PLACE OLR ACTED                  | OLR RESET  | 07:15:00             | 07:30:00             |                        |
| 2     | OHP  | WOBR ON CO-26 | B/W NOT RUNNING MPCB TRIP (2TIMES)                 | RESET  | 09:30:00<br>10:10:00 | 09:45:00<br>10:20:00 |                        |
| 3     | OHP  | TBS ON CO 5A  | LT NOT TAKING PLACE DUE TO PCRD CABLE OVER LAPPING | PCRD LAYERING ADJUSTED   | 10:00:00             | 10:30:00             |                        |
| 4     | OHP  | CO 29         | REPORTED RED OLR ACTED                             | RESET  | 10:30:00             | 10:40:00             |                        |
| 5     | OHP  | CO-84         | OLR ACTED  | RESET  | 12:20:00             | 12:30:00             |                        |
| 6     | OHP  | CO-33M        | OLR ACTED  | RESET  | 12:50:00             | 13:00:00             |                        |
| 7     | CHP  | CC 54         | OLR ACTED(3TIMES)                                  | RESET  | 07:40:00             | 07:50:00             | 10:40,11:30            |
| 8     | CHP  | CC-51         | STOPPING ON ZS DUE TO JAMMING                      | INFORM TO OPERATION  | 11:30:00             | 11:50:00             |                        |
| 9     | CHP  | CC-52         | OLR ACTED (2TIMES)                                 | RESET  | 12:10:00<br>12:50:00 | 12:20:00<br>13:00:00 |                        |
| 10    | CHP  | CC-26 F/G     | MPCB TRIP  | RESET  | 13:15:00             | 13:20:00             |                        |
| 11    | CHP  | CC-40 SCR-3   | B/C not running                                    | Signal missing.LT forward done and tested okay                                 | 09:30:00             | 09:40:00             |                        |
| 12    | CHP  | CC-33 SCR-4   | B/W not running                                    | Low charge pressure problem. Bypassed and informed to hydraulic in charge      | 10:00:00             | 10:10:00             | informed to mechanical |
| 13    | WT   | OP-1          | Reported no movement                               | Between Column no.11 and 12 insulator failed. Packing provided and tested okay | 13:00:00             | 14:00:00             |                        |
| 14    | WT   | CO-3(B/D)     | Reported not healthy                               | OLR acted. reset done(2 times)   | 07:00:00<br>10:00:00 | 07:15:00<br>10:15:00 |                        |
| 15    | WT   | OC-1A         | Reported not healthy                               | OLR acted. reset done  | 10:15:00             | 10:30:00             |                        |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

| Sl No | Area | Equipment | Problem            | Action              | From     | To       | Remarks               |
|-------|------|-----------|--------------------|---------------------|----------|----------|-----------------------|
| 16    | WT   | OT-2      | Initial not coming | Rollers got jammed. | 06:30:00 | 06:45:00 | informed to operation |