



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/09/2025

Area: CHP

Equipment	Job
BW-201	cc-201 Belt scale shift totaliser programming and display in CCR HMI done
Misc	COB-5 plc and siemens plc communication healthy status provided in CCR COB-5 HMI
CC-201,222,223 BELT SCALES	Belt scale units cleaning done
CC-45,46 T/E	Lighting supply rectification done
RECL-1, SCR-5	Machines interchanging done
CC-53 TT	Motors ppm done
CC-116,117	Motor meggar values taken and found ok
CC-115	motor and panel ppm done