



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------|----------|---------|
| 1 | OHP | CO-29 WBR | DOWN LIMIT ACTED | LUFF UP DONE THEN OK | 19:40:00 | 19:55:00 | |
| 2 | OHP | CO-67 | TRIPPED ON OLR | RESET DONE | 19:45:00 | 19:55:00 | |
| 3 | OHP | WBR ON CO -25 | YARD ZSS CAGE TIED WITH ROPE DURING BELT WORK | MADE FREE | 20:40:00 | 20:50:00 | |
| 4 | CHP | CC-37 SCR-3 | BC TRIPPED ON OLR | RESET DONE | 17:20:00 | 17:30:00 | |
| 5 | CHP | CC-32 | DRIVE END CHUT SENSOR CABLE GOT CUT | REJOINED | 18:45:00 | 19:00:00 | |
| 6 | CHP | CC-39 SCR-6 | SLEW NOT WORKING | MATERIAL JAMMING ... INFORMED OPERATION | 18:45:00 | 18:55:00 | |
| 7 | CHP | CC-223 | DRIVE TRIPPED ON OL | RESET DONE | 19:40:00 | 19:50:00 | |
| 8 | CHP | CC-32 SCR-5 | LT NOT WORKING .. PCRD OVER TENSION | RELEASED AND CABLE ADJUSTED | 19:10:00 | 19:25:00 | |
| 9 | WT | OT-4 | D-1 TRIPPED ON PGF-4 FAULT | RESET DONE | 19:25:00 | 19:30:00 | |
| 10 | IOSA | IOSA | COMMUNICATION PROBLEM | POWER RECYCLED IN OM-4 ; LC-3 ;OM-1 LC-1 | 16:25:00 | 17:35:00 | |