



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/02/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|-----------------------------------|----------|----------|---------|
| 1 | OHP | CO 36B | BRS NOT RESET DUE TO MATERIAL JAMMING | AFTER CLEANING THEN OK | 22:35:00 | 22:45:00 | |
| 2 | OHP | BRC ON CO 32 | OIL LEVEL LOW DUE TO OIL LEAKAGE | INFORMED TO MECH | 00:00:00 | 00:20:00 | |
| 3 | CHP | CC 131 | OLR ACTED | RESET | 05:40:00 | 05:45:00 | |
| 4 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 23:10:00 | 03:10:00 | 7 TIMES |
| 5 | CHP | CC 132 | OLR ACTED | RESET | 02:00:00 | 02:10:00 | |
| 6 | CHP | CC 114 | ZS ACTING DUE TO LOAD | AFTER CLEANING OK | 23:35:00 | 23:55:00 | |
| 7 | CHP | CC 203 | OLR ACTED | RESET | 01:30:00 | 01:40:00 | |
| 8 | CHP | SCR 5 ON CC 32 | B/C OLR ACTED | RESET | 03:55:00 | 04:05:00 | |
| 9 | CHP | SCR 5 ON CC 32 | B/C STOPPING FREQUENTLY DUE TO BELT LOOSE | INFORMED TO MECH FOR BELT TENSION | 05:30:00 | 05:45:00 | |