



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 19	l/luff olr acted	reset	08:40:00	08:50:00	
2	OHP	TT2 ON CO 21	POSITION INDICATION NOT SHOWING IN OCR PROXIMITY SWITCH BROKEN	SWITCH REMOVED THAN OK	08:45:00	09:10:00	
3	CHP	CC 117	OLR ACTED	RESET	08:50:00	09:00:00	
4	CHP	CC 105 SCR 10	stacking MODE NOT SHOWING in CCR	reclaiming mode fuse open in cm 18	06:30:00	06:35:00	
5	CHP	CC 104 SCR 9	slew not working,oil level low alarm in spider,sensor problem	informed operation and instrumentation	08:00:00	08:30:00	
6	CHP	CC 201	motor not running,olr acted in mpd	MPD reset	08:00:00	08:10:00	
7	CHP	CC 40 scr 6	B/C not running	fault reset in operator cabin	09:10:00	09:20:00	
8	CHP	cc 104 scr 9	b/c not running ,signal missing	LT done than ok	11:00:00	11:10:00	
9	CHP	CC 38 SCR 3	luffing not working,down limit acted	lever released than ok	12:20:00	12:30:00	