



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/05/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED (3TIMES)	RESET DONE	06:40:00	09:00:00	
2	OHP	TBS ON CO20	LT NOT WORKING PCRD O/T ACTED	RELESED	08:40:00	09:00:00	
3	OHP	CO 5	E/STOP BUTTON ELEMENT PROBLEM	REPLACED WITH NEW	10:15:00	10:30:00	
4	OHP	WOBR ON CO 6A	SLEWING NOT MOVING	WRONG COMPLMENT	10:30:00	10:40:00	
5	CHP	cc 32 scr5	b/c not running ,jamming,olr acted	ol reset and informed operation to clean	06:15:00	06:30:00	
6	CHP	CC 36	ZSS acted,module problem	new ZSS module replaced	07:35:00	08:20:00	
7	CHP	CC 44	OLR acted	reset it	09:20:00	09:25:00	
8	CHP	CC 34 SCR 2	LT not working,OT acted	OT released	10:00:00	10:10:00	PCRD guide roller problem informed mech
9	CHP	Cc 31 R1	B/c not running,zss cage stucked with coal	cage cleaned	07:30:00	07:45:00	
10	CHP	CC 40	ZSS acted,zss cage pin came out	cage pin fixed,return idler not present informed mech	13:35:00	13:45:00	