



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/06/2025

Area: CHP

Equipment	Job
CC-13,17,24	Motor and panel PPM done
CC 220/221	Lighting ckt problem rectified
CC 35 ,S1	PPM was done
SCR 10	New OFC cable laid from operator cabin to MCC IO rack and connected .Communication restored