



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/01/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	OLR ACTED	RESET	04:13:00	04:20:00	
2	OHP	co 34	olr acted	reset	00:15:00	00:25:00	
3	OHP	wobr on co 6A	BC not running,olr acted	reset	03:00:00	03:15:00	
4	OHP	brc on co31	b/w 1 not running, tripped in olr	reset	05:25:00	05:45:00	
5	OHP	co 26	olr acted	reset	04:05:00	04:10:00	
6	OHP	TT4	power mccb tripped PCRd cable old joint got damaged	rejointed	23:00:00	23:30:00	
7	CHP	cc 33 scr 3	Lt not working,pcrd cable OT acted	OT released	22:05:00	22:20:00	
8	CHP	cc 39 scr 6	slew not working,due to jamming	informed operation	22:25:00	22:35:00	
9	CHP	cc 223	not healthy,drive tripped	reset	01:10:00	01:25:00	
10	CHP	cc 132	motor tripped in olr	reset	00:05:00	05:25:00	3 times
11	CHP	cc 51	MPD TRIPPED 2 times	reset	23:55:00	00:25:00	
12	CHP	cc 52	mpd tripped 2 times	reset	00:10:00	00:30:00	
13	CHP	cc 131	olr acted	reset	05:10:00	05:15:00	
14	WT	OP2	no movement,d1 OLR acted	reset	23:35:00	23:55:00	
15	WT	OP2	no movement,D1 OLR acted	D1 coil connection removed	00:07:00	00:30:00	
16	WT	OT 2	D2 tripped 5 times on pgf1 fault	reset	01:50:00	03:00:00	