



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment                  | Problem  | Action           | From                             | To                               | Remarks |
|-------|------|----------------------------|--|------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | WBR ON<br>CO 25<br>SLEW    | DRIVE TRIPPED                                      | RESET            | 00:00:00                         | 00:15:00                         |         |
| 2     | OHP  | CO 29                      | OLR ACTED  | RESET            | 01:25:00                         | 01:30:00                         |         |
| 3     | OHP  | CO 26                      | OLR ACTED  | RESET            | 01:55:00<br>04:00:00             | 02:00:00<br>04:10:00             |         |
| 4     | OHP  | BRC ON<br>CO 32            | HYD PUMP NOT GETTING ON DUE TO<br>GLASS FUSE BLOWN | REPLACED THEN OK | 04:30:00                         | 05:45:00                         |         |
| 5     | OHP  | VF 1A                      | M1 OLR ACTED                                       | RESET            | 04:05:00<br>05:00:00<br>22:40:00 | 04:10:00<br>05:10:00<br>22:50:00 |         |
| 6     | OHP  | RSCO 10A<br>ZSS<br>ACTING  | PROBE CHECK NUT LOOSE                              | ADJUSTMENT DONE  | 22:40:00                         | 23:00:00                         |         |
| 7     | CHP  | SCR1 ON<br>CC 34 LT        | M1 TRIPPED   | MADE IT ON       | 01:10:00                         | 01:25:00                         |         |
| 8     | CHP  | SCR 9 ON<br>CC 104<br>SLEW | MPD ACTED  | RESET            | 02:10:00                         | 02:25:00                         |         |
| 9     | CHP  | SCR1 ON<br>CC 34           | LUFF UP LIMIT STUCKED                              | RELEASED         | 02:35:00                         | 02:50:00                         |         |
| 10    | CHP  | CC 125                     | OLR ACTED  | RESET            | 02:30:00                         | 02:45:00                         |         |
| 11    | CHP  | CC 28                      | OLR ACTED  | RESET            | 01:00:00<br>01:40:00             | 01:10:00<br>01:50:00             |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem              | Action | From     | To       | Remarks |
|-------|------|-----------|----------------------|--------|----------|----------|---------|
| 12    | CHP  | CC 51     | FEEDING CONV TRIPPED | RESET  | 00:50:00 | 06:00:00 | 8 TIMES |
| 13    | CHP  | CC 117    | OLR ACTED            | RESERT | 05:55:00 | 06:00:00 |         |
| 14    | CHP  | CC 54     | OLR ACTED            | RESET  | 23:00:00 | 03:00:00 | 4 TIMES |
| 15    | WT   | OT2       | DRIVE 2 PGF1 ACTED   | RESET  | 22:40:00 | 22:45:00 |         |