



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/08/2025

Area: CHP

| Equipment | Job |
|------------------|---|
| SCR 4 | Slew speed reduced on operation request |
| CC 37 | Drive end chute sensor modification done |
| CC 37 HT coupler | Maintenance was done ,replaced fuses and charged supply |
| VF level | LDB problems rectified and improved lighting |
| R and C Lab | Power cable laying under progress |
| JH C19,C212 | Hoist panels maintenance done |
| CC 108,VS2,VF2 | PPM was done |
| S1,SCR 7,SCR 10 | 3 nos machine shiftings were done |