



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/02/2026

Area: OHP

Equipment	Job
brc-4 on co-28	ppm is done
vf-1a and vf-2a	speed references have been checked and set, found ok.
CO-3A	mechanical brs spare bit (i105.6) at 1-141lc4 io rack is programmed and indication provided in HMI.