



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---|----------|----------|---------|
| 1 | OHP | BRC on CO 28 | bc stopping in ZSS, control wire loose in module | tightened | 11:45:00 | 11:59:00 | |
| 2 | CHP | cc 51 | mpd tripped 5 times | reser | 11:00:00 | 11:05:00 | |
| 3 | CHP | CC 58 | olr atced | reset | 07:30:00 | 07:45:00 | |
| 4 | CHP | CC 131 | olr acted | reset | 10:35:00 | 10:40:00 | |
| 5 | CHP | CC 33 STKR3 | slew left not working,limit acted | limit bypassed than ok,kept back in ckt | 07:20:00 | 07:40:00 | |
| 6 | CHP | CC 37 SCR3 | luff not working,oil level low | informed mech | 07:15:00 | 07:25:00 | |
| 7 | CHP | CC 223 | mccb tripped | made on | 08:45:00 | 08:55:00 | |
| 8 | CHP | CC 203 | olr acted | reset | 10:45:00 | 10:55:00 | |