



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/05/2025

Area: WT

Equipment	Job
CP 2	panel and motor side ppm done
OP 6	panel and motor side ppm done(Pads to be changed)
OP 1	Col no 75-76, Middle and bottom Bus bars adjusted as per pads position
OP 1,3,4 and 7	after rake maintenance done
SCO 1A	Pull card switch,removed and changed the location ,re fixed and kept in circuit