



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-84	OLR ACTED	RESET DONE	14:30:00	14:45:00	
2	OHP	CO-7A TBS	LUFF NOT WORKING	LIMIT TIED ... RELEASED	20:00:00	20:15:00	
3	OHP	BRC ON CO-31	BC OLR ACTED	RELEASED	20:12:00	20:24:00	
4	OHP	CO-6A	BRS NOT HEALTHY ... NO POWER IN BRS	BYPASSED	21:45:00	22:00:00	CHECKING GOING ON
5	CHP	CC-203	TRIPPED ON OLR	RESET DONE	15:20:00	15:25:00	
6	CHP	CC-108	TRIPPED ON OLR	RESET DONE	18:33:00	18:35:00	
7	CHP	CC-35 SCR-3	LT AND SLEW NOT WORKING	LT DRIVE TRIP ... RESET SLEW JAMMING	19:10:00	19:20:00	
8	CHP	SCR-2 CC-34	SLEW NOT WORKING	30 DEGREE ACTED ... BYPASSED AS PER OPERATION REQUEST	20:45:00	20:55:00	
9	CHP	CC-27	CHUT SENSOR ACTED	HEALTHY AFTER CLEANING	20:00:00	20:10:00	
10	CHP	CC-38 SCR-6	SIGNAL PROBLEM	LT DONE THEN OK	17:35:00	17:45:00	
11	IOSA	FLS WBR ON OC-18A	YARD INTERLOCK ZSS CAGE STONE STUCK	MADE FREE	18:00:00	18:10:00	