



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|------------------------------------------------------|---------------------------------------------|----------|----------|--------------------------------------------|
| 1 | OHP | BRC CO-28 | CT NOT WORKING ... LIMIT DAMAGED | CHANGED | 15:30:00 | 16:30:00 | |
| 2 | OHP | CO-6A WBR | BC NOT WORKING ... BSS ACTED DUE TO OFF CENTERING | ADJUSTED BY MECH | 17:15:00 | 18:00:00 | |
| 3 | OHP | WBR ON CO-25 | SLEW NOT WORKING | DRIVE TRIP ... RESET | 18:30:00 | 18:45:00 | |
| 4 | OHP | CO-30A | ZSS PROB DAMAGED | BYPASSED IN CJB AS PER OPERATION REQUEST | 21:00:00 | 21:10:00 | PROB TO BE CHANGED AT 10.00 PM |
| 5 | OHP | VF-17 | MOTOR SHAFT DAMAGED | CHANGING IN PROCESS | 20:40:00 | 22:00:00 | WORK GOING ON |
| 6 | CHP | CC-31 SCR-4 | LUFF NOT WORKING... DOWN LIMIT ACTED | RELEASED | 14:45:00 | 15:10:00 | |
| 7 | CHP | CC-38 SCR-6 | LT NOT WORKING | TRACK JAMMING .. INFORMED OPERATION | 15:20:00 | 15:30:00 | |
| 8 | CHP | CC-38 SCR-6 | LT NOT WORKING | DRIVE TRIPPED ... RESET | 17:28:00 | 17:32:00 | |
| 9 | CHP | CC-54 | TRIPPED 4 TIMES | RESET DONE | 17:57:00 | 20:00:00 | |
| 10 | CHP | ccc-222 | NOT RUNNING | JAMMING INFORMED OPERATION FOR CLEANING | 21:20:00 | 21:30:00 | |
| 11 | CHP | CC-34 SCR-2 | BC ZSS PROB PROBLEM | BYPASSED ... | 20:50:00 | 21:00:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------|------------|----------|----------|---------|
| 12 | WT | AF-3 | DRIVE TRIPPED | RESET DONE | 14:30:00 | 14:45:00 | |
| 13 | WT | AF-4 | DRIVE FAILED | CHANGED | 18:15:00 | 19:25:00 | |
| 14 | WT | SCO-1A CD | TRIPPED ON OLR | RESET DONE | 19:40:00 | 19:45:00 | |
| 15 | WT | OT-1 | D1 TRIPPED ON PFG1 FAULT | RESET DONE | 21:25:00 | 21:30:00 | |
| 16 | IOSA | BRC ON OC-16A | YARD ZSS CAGE STUCK | MADE FREE | 18:30:00 | 18:40:00 | |
| 17 | IOSA | OC-25A | TRIPPED ON OLR | RESET DONE | 17:00:00 | 17:15:00 | |