



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON -CO-26	PCRD NOT WORKING CHECKED AND FOUND CONTROL MCB FAIL,TIMER COIL WIRE GOT CUT	CONTROL MCB REPLACED AND TIMER COIL WIRE CONNECTED THAN OK	08:00:00	08:10:00	
2	OHP	BRC ON CO-32	REPORTED B/W S NOT RUNNING FOUND XMD TERMINATION PLUG PROBLEM	REPLACED WITH SPARE	12:00:00	13:00:00	
3	OHP	TT-3 ON CO-16	REPORTED SPARK OBSERVED FROM PCRD DRUM FOUND CABLE GOT CUT	JOINT DONE THAN OK	11:40:00	12:10:00	
4	OHP	CO-29	OLR ACTED	RESET DONE	13:30:00	13:40:00	
5	CHP	CC-29	TRIPPED ON OLR (2TIMES)	RESET DONE	06:20:00 08:15:00	06:30:00 08:25:00	
6	CHP	CC-51	MPD TRIPPED (2TIMES) FEEDING CONVEYOR	RESET DONE	10:00:00 12:05:00	10:05:00 12:10:00	
7	CHP	CC-51	OLR ACTED (2TIMES)	RESET DONE	10:00:00 12:05:00	10:05:00 12:10:00	
8	CHP	CC-54	TRIPPED ON OLR	RESET DONE	13:20:00	13:30:00	
9	CHP	CC-32 R-1	REPORTED LUFFING NOT WORKING CHECKED NO PROBLEM	INFORMED TO MECHANICAL	06:30:00	06:45:00	
10	CHP	CC-125	TRIPPED ON OLR	RESET DONE	10:00:00	10:05:00	
11	CHP	CC-39 SCR-2	LT NOT WORKING PCRD O/T ACTED (3TIMES)	RELEASED	09:45:00	12:10:00	
12	CHP	CC-35 SCR-3	LT NOT WORKING DRIVE TRIPPED	RESET DONE	11:50:00	12:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-34 SCR-1	REPORTED LT NOT TAKING PLACE M-2 TRIPPED	RESET DONE	11:30:00	11:40:00	
14	CHP	CC-35 SCR-3	LT NOT TAKING PLASCE PCRD O/T ACTED	RELEASED	13:50:00	14:00:00	
15	CHP	CC-31 SCR-4	LT NOT TAKING PLACE FOUND PCRD ON FEEDBACK NOT SHOW	BYPASSED	13:40:00	13:50:00	