



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-25	Luffing not taking place	OLR acted.Reset done	22:40:00	22:55:00	
2	OHP	WOBR on CO-29	Yard interlock problem	Wrong complaint	22:55:00	23:10:00	
3	OHP	BRC on CO-31	CT not taking place	CT chain fallen	23:20:00	23:30:00	Informed to mechanical
4	OHP	CO-59	Reported tripped	Wrong complaint	03:30:00	03:35:00	
5	OHP	VS-5A	Reported tripped	OLR acted.Reset done	05:05:00	05:10:00	
6	OHP	TBS on CO-21	LT not stopping	Mechanical brake in loose condition	00:00:00	00:10:00	Informed to mechanical
7	OHP	Stacker on CO-22	Reported boom signal missing	RMU panel relay and TB'S tightened.Antenna cleaning also done	23:45:00	00:27:00	
8	OHP	WOBR on CO-25	Luff up not taking place	24V DC missing in TB in luff panel.TB's tightened and tested okay	00:45:00	01:00:00	
9	CHP	CC-32 SCR-5	LT not taking place	Drive tripped.Reset done	03:30:00	03:45:00	
10	CHP	CC-223	Reported not running	Checked and found material selection not given in CCR.	03:20:00	04:00:00	Selection provided and tested okay.Not an electrical problem
11	CHP	Cc-28	Reported tripped	OLR acted.Reset done	01:50:00	02:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-19	Reported tripped	OLR acted.Reset done	02:30:00	02:35:00	
13	CHP	CC-29	Reported tripped	OLR acted.Reset done	05:28:00	05:32:00	
14	CHP	CC-51	MPD acted	Reset done(12 times)	23:50:00	05:35:00	
15	CHP	CC-132	ZSS acting	ZSS cage stuck with stone.Made free and tested okay	01:00:00	01:20:00	
16	IOSA	All conveyors red	Communication problem	LC-3,OM-4,LC-1,OM-1 and LC-9 NIU power recycled but LC-9 rack problem.	02:00:00	06:30:00	