



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/06/2025

Area: IOSA

Equipment	Job
OC-9A	LIGHTING CIRCUIT DEFECTS RECTIFIED.
MISC	ETHERNET CABLE MADE READY FOR OC-11A RMU PANEL.
OC-16A and OC-18A	BRAKE PANEL GOT RUSTED AND DAMAGED SO REMOVED AND SHIFTED TO ELECTRICAL SHED.