



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/05/2025

Shift: A

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	TRIPPED ON OLR	RESET DONE	07:35:00 10:15:00 13:00:00	07:45:00 10:20:00 13:10:00	
2	OHP	CO-29	TRIPPED ON OLR	RESET DONE	08:40:00	08:50:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	08:50:00	09:00:00	
4	OHP	CC-32 SCR-5	BC STOPPING FREQUENTLY	PLC POWER RECYCLED	12:30:00	13:00:00	
5	CHP	CC-36 SCR-1	LT END LIMIT BYPASS REQ FROM OPERATION	BYPASSED	07:20:00	08:00:00	AGAIN KEPT IN CKT
6	CHP	CC-107	TRIPPED IN OLR	RESET DONE	09:27:00 12:15:00	09:30:00 12:20:00	
7	CHP	CC-54	TRIPPED ON OLR	RESET DONE	08:00:00	08:05:00	
8	CHP	CC-131	TRIPPED IN OVER LOAD	RESET DONE	07:10:00	07:15:00	
9	CHP	CC-33	BRS BYPASS REQ	BYPASSED IN SYSTEM	13:00:00	13:05:00	
10	CHP	CC-107	BRS FREQUENTLY ACTING IN EMPTY BELT ALSO	BYPASSED IN SYSTEM	10:30:00	10:45:00	TO BE CHECKED
11	WT	OP-8	DRIVE 2 TRIPPING CONTINUOUSLY	D2 POWER MADE OFF AND HEALTHY AND FEEDBACK BYPASSED AND TESTED	08:40:00	09:00:00	
12	WT	SCO-1A	STOPPING ON ZSS FAULT	MODULE POWER SUPPLY PROBLEM .... BYPASSED	13:20:00	13:30:00	TO BE CHECKED