



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/11/2025

Area: WT

Equipment	Job
OT 4	LS 1,replaced with new and tested,bypass removed
OT 4	Initial indication,target(BOLT) position changed and adjusted probe accordingly
OP 6	Motor side ppm done
OP 2,3,4,5 and 8	After rake, maintenance done