



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/06/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset done	22:15:00	22:20:00	
2	OHP	WOBR on CO 6A	BW overload acted	reset done	22:40:00	22:55:00	
3	OHP	TBS on CO 21	LT not moving	M4 overload acted, reset done	23:15:00	23:30:00	
4	OHP	CO 35	OLR acted	reset done	23:35:00	23:45:00	
5	OHP	RSCO 1A	Stopped on zss	Probe damaged, changed	23:30:00	00:00:00	
6	OHP	WOBR on CO 29	BC not running	Interlock ZSS cage stuck up with stone , made free	02:35:00	02:45:00	
7	OHP	TBS on CO21	Chute sensor malfunctioning	Bypassed	04:45:00	05:05:00	
8	OHP	CO 3B	Not healthy of pull chord	All pull chord switch reset condition , then bypassed	23:40:00	00:20:00	
9	OHP	CC 33 , SCR 4	BC chute sensor acting due to rain	Bypassed	05:45:00	05:50:00	in system
10	CHP	CC 32	TUL chute sensor acting due to rain	Bypassed	01:25:00	01:35:00	in system
11	CHP	CC 33	TUL chute sensor acting due to rain	Bypassed	02:45:00	02:55:00	in system
12	CHP	CC 201	OLR acted	reset done	23:45:00	00:10:00	
13	CHP	CC 31 , S-3	LT not working	Drive tripped, reset done	01:10:00 02:25:00	01:24:00 02:35:00	
14	CHP	CC 34, SCR 2	LT not working	Overtension acted, released. Also drive tripped, reset done	23:30:00	23:45:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 32 , SCR 5	Luffing lower limit bypassed as per operation request	After operation work again kept in circuit	23:30:00	23:45:00	