



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset done	15:40:00 18:15:00	15:50:00 18:25:00	
2	OHP	CR 1A	Stopped on ZSS	Probe prblm, changed	14:35:00	15:00:00	
3	OHP	CO 35	OLR acted	reset done	18:45:00	18:55:00	
4	OHP	TBS on CO 22	LT not moving and BC not running	LT Drive tripped , reset done . BC mccb off , made on	20:10:00	20:30:00	
5	CHP	CC 35 , SCR 1	Boom position not coming in GVM side	position bypassed in IO rack	16:15:00	16:35:00	Informed to Gen shift
6	CHP	CC 35 , S 1	LT not working due to pcrd overtension acted	released, then ok	16:30:00	16:45:00	
7	CHP	CC 125	Tripped on overload	reset done	17:30:00	17:40:00	
8	CHP	CC 51	OLR acted (5 times)	reset done	17:20:00	21:20:00	
9	CHP	CC 58	Tripped on fault 'current sp'	reset done	19:40:00	19:55:00	
10	CHP	CC 18	OLR acted (2 times)	reset done	14:30:00	15:00:00	
11	CHP	CC 29	OLR acted (2 times)	reset done	18:50:00	19:05:00	
12	CHP	CC 28	OLR acted	reset done	18:50:00	18:55:00	
13	CHP	CC 19 , CC 26	BRS bypass request by operation	bypass done	16:28:00	16:36:00	in system
14	WT	OP 2 and OP 6	Not moving	Emergency acted , released	19:45:00	20:00:00	
15	WT	OP 2	D 5 overload acted	reset done	20:05:00	20:15:00	
16	WT	CO 3	Belt drive overload acted	reset done	15:30:00	15:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	WT	CT 2	Inhaul tripped	reset done	21:50:00	22:00:00	