



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-9	OLR ACTED(2TIMES)	RESET DONE	16:05:00 17:10:00	16:10:00 17:20:00	
2	OHP	CO-67	OLR ACTED	OLR RESET DONE	18:00:00	18:10:00	
3	OHP	TT-3 ON CO-21	POSITION INDICATION MISSING DUE TO CHUTE JAMMING	POSITION INDICATION BYPASSED AFTER CLEARING THE MATERIAL AGAIN KEPT IN CIRCUIT	14:45:00	15:00:00	
4	OHP	F/G -18	REPORTED NOT MOVING	CHECKED AND FOUND POWER OFF CONDITION NO FUSSES. FUSSES REPLACED AND POWER MADE ON THEN TESTED OK	16:35:00	17:00:00	
5	OHP	CO-16	REPORTED NOT HEALTHY	MPD TRIP RESET DONE THEN OK	20:30:00	20:40:00	
6	CHP	CC-37	TRIPPED ON OLR	RESET DONE	14:30:00	14:40:00	
7	CHP	CC-32 SCR-5	B/C NOT RUNNING OLR ACTED	RESET DONE THEN OK	14:55:00	15:10:00	
8	CHP	CC-31	REPORTED BRS FREQUENTLY ACTED	BRS SENSORS CLEANED THAN OK	16:15:00	16:40:00	
9	CHP	CC-37 SCR-7	LT NOT TAKING PLACE CHECKED AND FOUND MPCB 5AND 6 TRIP	RESET DONE THAN OK	16:20:00	16:30:00	DUE TO TRACK JAMMING
10	CHP	CC-105 SCR-10	B/C NOT RUNNING CHECKED MCCB TRIP AND DISCHARGE CHUTE SENSOR ACTED	MCCB MADE ON AND SENSOR CLEANED THAN OK	17:30:00	17:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC-36 SCR-1	SLEW NOT WORKING CHECKED 30 RIGHT LIMIT ACTED	LIMIT BY PASSED AND AGAIN KEPT IN LINE AFTER CLEANING	17:55:00	18:15:00	SLEW AREA MOTOR SIDE FULL JAMMING INFORMED TO OPERA TION
12	CHP	CC-39	OLR ACTED	RESET DONE	18:20:00	18:25:00	
13	CHP	CC-37 SCR-7	LT MPCB 3,5,6 TRIP	RESET DONE DUE TO TRACK JAM INFORM TO OPERATION	19:00:00	19:15:00	
14	CHP	CC-37 SCR-7	SLEW SPIDER BREAK FAIL ALARM TRIP	RESET DONE	19:15:00	19:25:00	
15	CHP	CC-54	OLR ACTED(3TIMES)	RESET DONE	14:20:00 17:15:00 20:00:00	14:25:00 17:20:00 20:15:00	
16	CHP	CC-51	OLR ACTED(6TIMES)	RESET DONE	15:25:00	19:55:00	
17	CHP	CC-131	OLR ACTED	RESET DONE	19:00:00	19:10:00	
18	CHP	CC-113	STOPPING ON ZSS	BELT SNAP INFORM TO OPERATION	20:45:00	21:00:00	
19	CHP	CC-27A F/G	MPCB TRIPPED DUE TO CHUTE JAMMING	INFORMED TO OPERATION	14:20:00	14:30:00	
20	CHP	CC-26 TT	REPORTED POSITION INDICATION NOT COMING FOR CC-34 CHUTE	TT NOT POSITIONED PROPERLY.AFTER POSITIONING FOUND OKAY	17:05:00	17:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/09/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
21	CHP	CC-36 SCR-1	SLEW NOT MOVING	LEFT LIMIT ACTED DUE TO JAMMING	21:40:00	22:00:00	INFORMED TO OPERATION TO CLEAR JAMMING
22	CHP	CC-125	REPORTED NOT HEALTHY	OLR ACTED. RESET DONE	21:00:00	21:08:00	
23	WT	OP-4	NOT MOVE CHECKED D-3 TRIP (2TIMES)	RESET DONE	18:05:00 18:50:00	18:15:00 19:00:00	
24	WT	OP-4	NOT MOVE D-6 MOTOR LUG CUT IN TB	RE LUGGING AND TERMINATED THAN OK	19:00:00	20:00:00	