



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|-----------------------------------|----------|----------|---------------------------|
| 1 | OHP | BRC ON CO-8A | REPORTED B/W-1 STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE DAMAGED | ZSS BYPASSED | 07:20:00 | 07:35:00 | DUE TO MECHANICAL PROBLEM |
| 2 | CHP | TT ON CC-102 | REPORTED TT NOT MOVED CHECKED AND FOUND PCRD CABLE OLD JOINT GOT CUT | PCRD CABLE JOINT WAS DONE THAN OK | 08:30:00 | 09:20:00 | |
| 3 | CHP | CC-51 | MPD TRIPPED ON OLR (3TIMES) DUE TO FEEDING CONVEYOR STOP | RESET DONE | 13:00:00 | 13:25:00 | |
| 4 | CHP | CC-54 | TRIPPED ON OLR (3TIMES) | RESET DONE | 09:15:00 | 11:00:00 | |
| 5 | CHP | CC-58 TT | REPORTED NOT HEALTHY FESTOON CONTROL CABLE DAMAGED | RE-JOINT DONE THAN OK | 10:30:00 | 10:50:00 | |
| 6 | CHP | CC-51 | TRIPPED ON OLR | RESET DONE | 13:25:00 | 13:30:00 | |
| 7 | CHP | CC-35 SCR-3 | SLEW NOT WORKING CHECKED AND FOUND R/LIMIT ACTED DUE TO JAMMING | INFORMED TO OPERATION | 10:30:00 | 10:40:00 | |
| 8 | WT | OT-1 | REPORTED NOT MOVE DRIVE -1 PGF-1 FAULT | RESET DONE | 12:45:00 | 12:55:00 | |
| 9 | WT | OC-1A | TRIPPED ON OLR | RESET DONE | 08:45:00 | 09:00:00 | |
| 10 | IOSA | WOBR | REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED | RELEASED THAN OK | 12:30:00 | 12:40:00 | |