



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/06/2025

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO7	CTMF RELAY ACTED	RESET	10:15:00	10:35:00	
2	CHP	ALL MACHINE SIGNALS NOT COMING	SIEMENS TO MICROLOGIX HEALTHY BIT NOT COMING	PROCESSOR C WARM RESTART	08:15:00	08:25:00	
3	CHP	SCR1 ON CC 36	B/C OLR ACTED	RESET	08:10:00	08:25:00	
4	CHP	R1 ON CC31	B/C NOT RUNNING	FAULT RESET THEN OK	09:15:00	09:25:00	
5	CHP	SCR 1 ON CC 36 SLEW	DRIVE TRIPPING FREQUENTLY DUE TO ONE MOTOR GOT BURNT	INFORMED G SHIFT	10:20:00	11:00:00	
6	CHP	SCR2 ON CC 35	PCRD CABLE GOT STUCKED AND O/T ACTING	CABLE REMOVED PROPERLY	11:30:00	12:00:00	
7	CHP	SCR 9 ON CC 104 B/C SIGNAL MISSING FREQUENTLY	NEW CAGE FIXED FOR CAGE INTERLOCK AND RECLAIMING MODE BIT MADE HIGH IN CM 18	THEN OK	09:30:00	10:30:00	
8	CHP	SCR 2 ON CC 35	LT DRIVE TRIPPED	RESET	13:15:00	13:30:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/06/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
9	CHP	CC 131	OLR ACTED	RESET	07:15:00 10:25:00 12:00:00	07:20:00 10:30:00 12:05:00	
10	CHP	CC 130 MD	ACTING FREQUENTLY	SENSITIVITY ADJUSTED	08:30:00	09:00:00	
11	CHP	CC 54	OLR ACTED	RESET	10:25:00 10:40:00	10:35:00 10:45:00	
12	CHP	CC 51	OLR ACTED TAIL END JAMMING	RESET INFORMED TO OPRN	10:55:00	11:00:00	