



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/09/2025

Area: WT

| Equipment | Job   |
|-----------|---|
| MIS       | Coupling fixed to 37 KW spare motor and End cover bolts found loose,tightening done |
| OT 1      | In LDB, lug replaced to neutral cable and tightening done                           |
| OP 10     | control circuit checked and lighting improved                                       |
| OP 1      | After rake maintenance done   |