



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/09/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11(C/D)	Reported tripped	MPCB tripped.Made on	07:20:00	07:30:00	
2	OHP	RSCO-10A(B/D)	Reported tripped	OLR acted.Reset done	13:20:00	13:24:00	
3	OHP	CO-29	Reported tripped	OLR acted.Reset done	07:30:00	07:45:00	
4	CHP	cc 54	OLR ACTED	RESET	10:00:00	10:05:00	
5	CHP	CC 51	OLR MPD ACTED TO STOP FEEDING CONVEYOR	RESET	08:15:00 10:20:00	08:20:00 10:25:00	
6	CHP	CC-29	Reported tripped	Olr acted.Reset done	07:40:00	07:45:00	
7	CHP	CC 37 SCR 7	LT NOT WORKING M3 M5 M6 TRIP	MADE IT ON	06:30:00 11:40:00	06:45:00 11:55:00	
8	CHP	S 1 ON CC 33	SLEW LIMIT ACTED	RELEASED THEN OK	07:05:00	07:20:00	
9	CHP	CC 125	OLR ACTED	RESET	09:00:00	09:05:00	
10	CHP	CC 108	OLR ACTED	RESET	09:15:00	09:20:00	
11	WT	OP-7	Reported not moving	Movement done from dead end keeping in local and then kept in PLC and tested okay	10:00:00	10:05:00	
12	IOSA	OC-36A	Reported not healthy	Checked and found P/C and E-stop not healthy.Bypassed and given clearance.Checking is going on.	06:00:00	06:20:00	
13	IOSA	OC-13A	Reported stopping on CJD fault	TBS modem communication problem found.Modem to antenna cable changed and tested okay	12:00:00	13:00:00	