



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment   | Problem                          | Action   | From     | To       | Remarks              |
|-------|------|-------------|----------------------------------|--|----------|----------|----------------------|
| 1     | OHP  | CO 29       | OLR ACTED                        | RESET DONE   | 17:10:00 | 17:20:00 |                      |
| 2     | OHP  | CO-31 BRC   | BC NOT RUNNING ... EM PB ACTED   | RELEASED   | 15:40:00 | 16:00:00 |                      |
| 3     | OHP  | CO 32 BRC   | LT M4 OLR ACTED                  | RESET DONE   | 18:00:00 | 18:15:00 |                      |
| 4     | CHP  | CC-32 SCR-5 | LUFF NOT WORKING                 | CHANGED STANDBY TO MAIN THEN TESTED INFORMED MECH FOR STAND BY PUMP CHECKING | 15:15:00 | 16:00:00 |                      |
| 5     | CHP  | CC-35 SCR-3 | BC NOT RUNNING                   | MPD TRIPPED ... RESET  | 19:00:00 | 19:10:00 |                      |
| 6     | CHP  | CC-34 SCR-1 | LT NOT WORKING ... PCRD OT ACTED | RELEASED   | 20:50:00 | 21:00:00 |                      |
| 7     | CHP  | CC-51       | MPD TRIPPED 9 TIMES              | RESET DONE   | 16:50:00 | 21:40:00 |                      |
| 8     | CHP  | CC-54       | OLR ACTED 10 TIMES               | RESET DONE   | 19:30:00 | 21:35:00 |                      |
| 9     | CHP  | CM-15 CM-16 | COMMUNICATION PROBLEM            | WORK GOING ON  | 15:00:00 | 22:00:00 |                      |
| 10    | CHP  | CO-28 BRC   | CT NOT WORKING                   | MCC SIDE CT LIMIT STRIKER DAMAGED  | 21:10:00 | 22:00:00 | STRIKER TO BE WELDED |
| 11    | WT   | CO-3        | OLR ACTED                        | RESET DONE   | 15:30:00 | 15:40:00 |                      |