



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-61	TRIPPED ON STL FAULT	REST DONE --- R PHASE TIGHTENING DONE	02:45:00	05:50:00	R PHASE GETTING HEAT NEAR MOTOR TO BE CHECKED
2	OHP	CO-35	TRIPPED ON OLR	RESET DONE	04:00:00	04:05:00	
3	CHP	CC-114	TRIPPED ON OLR	RESET DONE	02:40:00	02:50:00	
4	CHP	CC-51	MPD TRIPPED	RESET DONE	02:47:00	02:57:00	
5	CHP	CC-131 TIS	BYPASS REQUEST	BYPASSED	23:40:00	23:45:00	
6	CHP	CC-28	TRIPPED ON OLR	RESET DONE	22:30:00	22:40:00	
7	CHP	CC-27	TRIPPED ON OLR	RESET DONE	22:55:00	23:05:00	
8	CHP	CC-40 SCR-3	BC NOT RUNNING	CHUT JAM INFORED FOR CLEANING	01:30:00	01:45:00	
9	CHP	CC-32	TRIPPED ON OLR	RESET DONE	01:50:00	02:10:00	
10	CHP	CC-125	TRIPPED ON OLR	RESET DONE	02:45:00	02:55:00	
11	WT	OP-10	BUS COUPLER AND OP -10 FEEDING BREAKER TRIPPED .. C AND U CLAMP DAMAGED	ACB PROBLEM ... REPLACED .. C AND U CLAMP REPLACED	23:15:00	01:00:00	
12	WT	OP-9	MIDDLE PAD ,C AND U CLAMP AND CABLE LUG DAMAGED .. BUS BAR BENT NEAR COLUMN NO 25-26	POWER BLOCK TAKEN AND PAD .. C AND U CLAMP AND LUG CHANGED AND TESTED	01:10:00	03:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OT-5	DRIVE-1 PROBLEM	DRIVER CHANGED AND TESTED	22:30:00	03:00:00	
14	IOSA	L and T WOB	Pump not starting found LS4 not healthy	reset done	02:10:00	02:12:00	