



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 18	OLR acted	reset done	00:25:00	00:40:00	
2	OHP	CO 8	BRS bypass request	BRS already in bypassed condition , BYPASSED in IO rack	01:40:00	01:50:00	
3	OHP	BRC on CO 28	LT not working due to overtension acted 2nd time OLR acted.	released. OLR reset done	05:15:00 23:15:00	05:30:00 23:40:00	
4	OHP	BRC on CO 28	BC not running due to OLR	RESET done	00:40:00 01:25:00	00:55:00 01:50:00	
5	OHP	BRC on CO 28	BW not running due to OLR acted	reset done	01:50:00	02:05:00	
6	OHP	CO 66	Conveyor not running	checked, motor running but fluid coupling output not running . Informed mechanical	05:20:00	05:40:00	
7	OHP	WOBR on CO 6A	Hydraulic pump stopping on CP1 and ACC 1 fault	CP1 bypassed and shown to mechanical that charge pressure is dropping . Then bypass removed	01:00:00	01:30:00	
8	OHP	CO 16	OLR acted	reset done	05:30:00	05:35:00	
9	OHP	CC 113A	Tripped on overload	reset done	02:00:00 03:20:00	02:10:00 03:40:00	
10	CHP	CC 31	Tripped on overload	reset done	22:10:00 23:15:00	22:25:00 23:30:00	
11	CHP	CC 39 , S 1	Luffing not working	No electrical problem . Air lock problem, informed to mechanical	23:50:00	00:10:00	
12	CHP	CC 104 , SCR 9	LT not working due to PCRD overtension acted	tension released	04:20:00 05:00:00	04:30:00 05:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 17	OLR acted	reset done	02:20:00	02:25:00	
14	CHP	CC 54	Tripped on overload	reset done	03:15:00 03:25:00	03:20:00 03:35:00	
15	WT	SCO 1A	Belt drive tripped on overload due to jamming ( 2 times)	reset done	04:30:00	04:40:00	