



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/12/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	10:40:00	10:45:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	10:10:00	10:20:00	
3	OHP	CO-9A	REPORTED STOPPING ON ZSS FOUND ZSS PROBE DAMAGED	PROBE REPLACED WITH NEW ONE THAN OK	10:50:00	11:15:00	
4	OHP	BRC ON CO-32	REPORTED B/W-1 NOT RUNNING FOUND GUIDE ROLLER PROBLEM	INFORMED TO OPERATION	07:05:00	07:20:00	
5	OHP	BRC ON CO-28	REPORTED ALL DRIVES ARE NOT RUNNING FOUND E/STOP ACTED	RELEASED	07:30:00	07:45:00	
6	OHP	WOBR ON CO-25	REPORTED B/W NOT RUNNING FOUND POWER MCCB TRIPPED	B/W MOTOR BURNT	11:30:00	12:00:00	G SHIFT ATTENDED
7	CHP	CC-117	OLR ACTED (2TIMES)	RESET DONE	06:05:00 10:15:00	06:15:00 10:25:00	
8	CHP	CC-51	MPD ACTED FEEDING CONVEYOR (6TIMES)	RESET DONE	08:00:00	11:15:00	
9	CHP	CC-52	MPD TRIPPED (FEEDING CONVEYOR)	RESET DONE	12:50:00	12:55:00	
10	CHP	CC-54	OLR ACTED	RESET DONE	08:40:00	08:45:00	
11	CHP	CC-39 SCR-6	REPORTED LT NOT WORKING FOUND DRIVE TRIP FAULT CODE OF-7404	RESET DONE	07:00:00	07:10:00	
12	CHP	CC-39 SCR-6	LT DRIVE TRIP FAULT CODE OF-30002	RESET DONE	07:50:00	08:00:00	
13	CHP	CC-32 SCR-5	B/C NOT RUNNING BELT SLIPPING	INFORMED TO MECHANICAL	07:45:00	07:55:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-32 SCR-5	B/C TRIPPED ON OLR	RESET DONE	08:40:00	08:50:00	
15	CHP	CC-33 SCR-3	B/W NOT RUNNING	FAULT RESET DONE THAN OK	09:00:00	09:10:00	
16	CHP	CC-40 SCR-2	SLEW NOT WORKING FOUND DRIVE TRIP AND 30 DEGREE LIMIT ACTED	RELEASED AND DRIVE RESET DONE	11:25:00	11:40:00	
17	WT	OT-4	DRIVE -2 TRIP PGF-4 FAULT	RESET DONE	13:55:00	14:00:00	