



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/08/2025

Area: CHP

Equipment	Job
CC 45	ZSS kept ion ckt
SCR 2,4,5,8	Instrumentation switches inspection done
CC 35	Burnt motor coupling removed and sent to ERS
All JHs	Dewatering inspected
CC 41/42 tunnel	Lighting improved
CC 42,36,S 2,37	PPM was done